

Detailed Latest Test Results



SEAWARD
ELECTRICAL SAFETY TESTING & MEASURING.

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 04/12/2023 To: 01/01/2024

Site: Snap Booth

Location: production

Asset ID: 00000343	Description: iec lead	User: admin	Test Instrument: Seaward Apollo 500 Plus 46N-0860
--------------------	-----------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	07/12/2023			Pass
Flex	07/12/2023			Pass
Enclosure	07/12/2023			Pass
Environment	07/12/2023			Pass
Socket	07/12/2023			Pass
Switch	07/12/2023			Pass
Voltage	07/12/2023	230	V	Information
IEC Lead Continuity	07/12/2023	0.07	ohm	Pass
Insulation Voltage	07/12/2023	500	V	Information
Insulation	07/12/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	07/12/2023			Pass

Overall: Pass

Asset ID: 00000344	Description: printer	User: admin	Test Instrument: Seaward Apollo 500 Plus 46N-0860
--------------------	----------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	07/12/2023			Pass
Flex	07/12/2023			Pass
Enclosure	07/12/2023			Pass
Environment	07/12/2023			Pass
Socket	07/12/2023			Pass
Switch	07/12/2023			Pass
Voltage	07/12/2023	230	V	Information
Insulation Voltage	07/12/2023	250	V	Information
Insulation	07/12/2023	> 19.99	MOhm	Pass
Live Voltage	07/12/2023	244.2	V	Information
Load Current	07/12/2023	0.157	A	Information
Touch Current	07/12/2023	0.02	mA	Pass

Overall: Pass

Asset ID: 00000345	Description: x lead	User: admin	Test Instrument: Seaward Apollo 500 Plus 46N-0860
--------------------	---------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	07/12/2023			Pass
Flex	07/12/2023			Pass
Enclosure	07/12/2023			Pass
Environment	07/12/2023			Pass
Socket	07/12/2023			Pass

Overall: Pass

Detailed Latest Test Results



SEAWARD
ELECTRICAL SAFETY TESTING & MEASURING.

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 04/12/2023 To: 01/01/2024

Switch	07/12/2023			Pass
Voltage	07/12/2023	230	V	Information
IEC Lead Continuity	07/12/2023	0.07	ohm	Pass
IEC Lead Continuity	07/12/2023	0.07	ohm	Pass
IEC Lead Continuity	07/12/2023	0.06	ohm	Pass
IEC Lead Continuity	07/12/2023	0.06	ohm	Pass
Insulation Voltage	07/12/2023	500	V	Information
Insulation	07/12/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	07/12/2023			Pass

Overall: Pass

Asset ID: 00000346	Description: photo booth	User: admin	Test Instrument: Seaward Apollo500 Plus 46N-0860
--------------------	--------------------------	-------------	--

Comments:

Test Type	Date	Result	Unit	Status
Plug	07/12/2023			Pass
Flex	07/12/2023			Pass
Enclosure	07/12/2023			Pass
Environment	07/12/2023			Pass
Socket	07/12/2023			Pass
Switch	07/12/2023			Pass
Voltage	07/12/2023	230	V	Information
Insulation Voltage	07/12/2023	250	V	Information
Insulation	07/12/2023	> 19.99	MOhm	Pass
Live Voltage	07/12/2023	240.9	V	Information
Load Current	07/12/2023	0.112	A	Information
Touch Current	07/12/2023	0.02	mA	Pass

Overall: Pass

Total Tests: 4