

Detailed Latest Test Results



Test Status: All, Test Type: All
Person: All, Instrument: All From:
04/12/2024 To: 01/01/2025

Site: Snap Booth

Location: production				
Asset ID: 00000343	Description: iec lead	User: admin	Test Instrument: Seaward Apollo 500 Plus 46N-0860	
Comments:				
Test Type	Date	Result	Unit	Status
Plug	07/12/2024			Pass
Flex	07/12/2024			Pass
Enclosure	07/12/2024			Pass
Environment	07/12/2024			Pass
Socket	07/12/2024			Pass
Switch	07/12/2024			Pass
Voltage	07/12/2024	230	V	Information
IEC Lead Continuity	07/12/2024	0.07	ohm	Pass
Insulation Voltage	07/12/2024	500	V	Information
Insulation	07/12/2024	> 19.99	MOhm	Pass
IEC Lead Polarity	07/12/2024			Pass
				Overall: Pass

Asset ID: 00000344	Description: printer	User: admin	Test Instrument: Seaward Apollo 500 Plus 46N-0860	
Comments:				
Test Type	Date	Result	Unit	Status
Plug	07/12/2024			Pass
Flex	07/12/2024			Pass
Enclosure	07/12/2024			Pass
Environment	07/12/2024			Pass
Socket	07/12/2024			Pass
Switch	07/12/2024			Pass
Voltage	07/12/2024	230	V	Information
Insulation Voltage	07/12/2024	250	V	Information
Insulation	07/12/2024	> 19.99	MOhm	Pass
Live Voltage	07/12/2024	244.2	V	Information
Load Current	07/12/2024	0.157	A	Information
Touch Current	07/12/2024	0.02	mA	Pass
				Overall: Pass

Asset ID: 00000345	Description: x lead	User: admin	Test Instrument: Seaward Apollo 500 Plus 46N-0860	
Comments:				
Test Type	Date	Result	Unit	Status
Plug	07/12/2024			Pass
Flex	07/12/2024			Pass
Enclosure	07/12/2024			Pass
Environment	07/12/2024			Pass
Socket	07/12/2024			Pass
				Overall: Pass

Detailed Latest Test Results



Test Status: All, Test Type: All
Person: All, Instrument: All From:
04/12/2024 To: 01/01/2025

Switch	07/12/2024			Pass
Voltage	07/12/2024	230	V	Information
IEC Lead Continuity	07/12/2024	0.07	ohm	Pass
IEC Lead Continuity	07/12/2024	0.07	ohm	Pass
IEC Lead Continuity	07/12/2024	0.06	ohm	Pass
IEC Lead Continuity	07/12/2024	0.06	ohm	Pass
Insulation Voltage	07/12/2024	500	V	Information
Insulation	07/12/2024	> 19.99	MOhm	Pass
IEC Lead Polarity	07/12/2024			Pass
				Overall: Pass

Asset ID: 00000346	Description: photo booth	User: admin	Test Instrument: Seaward Apollo 500 Plus 46N-0860	
Comments:				
Test Type	Date	Result	Unit	Status
Plug	07/12/2024			Pass
Flex	07/12/2024			Pass
Enclosure	07/12/2024			Pass
Environment	07/12/2024			Pass
Socket	07/12/2024			Pass
Switch	07/12/2024			Pass
Voltage	07/12/2024	230	V	Information
Insulation Voltage	07/12/2024	250	V	Information
Insulation	07/12/2024	> 19.99	MOhm	Pass
Live Voltage	07/12/2024	240.9	V	Information
Load Current	07/12/2024	0.112	A	Information
Touch Current	07/12/2024	0.02	mA	Pass
				Overall: Pass

Total Tests: 4